

Analýza odpadových vôd 2021

*v zmysle IPKZ 12 , 477-3523/2020/Tit/374860108/Z12 a Rozhodnutia SIŽP č.5142/27/2020-28119/2021

MESIAC :					Január		Február		Marec		Apríl		Máj		Jún		Júl		August	
Dátum odberu	Typ vzorky	Interval	Limity	Jednotky	15.1.2021	15.1.2021	10.02.2021	10.02.2021	17.03.2021	17.3.2021	21.04.2021	21.04.2021	25.05.2021	24.05.2021	24.06.2021	24.06.2021	14.07.2021	14.07.2021	11.08.2021	11.08.2021
					bodová vzorka	24- h. odber	bodová vzorka	24- h. odber	bodová vzorka	24- h. odber	bodová vzorka	24- h. odber	bodová vzorka	24- h. odber	bodová vzorka	24- h. odber	bodová vzorka	24- h. odber	bodová vzorka	24- h. odber
UGH Zberná nádrž																				
pH	24-h.	12x ročne	6,0 - 9,0	mg/l		6.27		7.59		8.06		7.71		7.24		7.56		6.99		8.01
CHSK _{cr} (COD)	24-h.	12x ročne	40	mg/l		34.8		32.4		38.4		31.2		36		48		26.4		24
NL	24-h.	12x ročne	40	mg/l		2.2		4.5		9.3		3.3		2.3		2.3		7.2		3.5
RL ₅₀₀	24-h.	12x ročne	1000	mg/l		575		595,0		799		401,0		443		462		418		550
NEL (UV)	bodová	12x ročne	0,1	mg/l	< 0.05		< 0.05		< 0.05		< 0.05		< 0.05		< 0.05		< 0.05		< 0.05	
NEL (IR)	bodová	12x ročne	0,1	mg/l	< 0.05		< 0.05		< 0.05		< 0.05		< 0.05		< 0.05		< 0.05		< 0.05	
AOX	bodová	12x ročne	0,5	mg/l	< 0.03		< 0.03		< 0.03		< 0.03		< 0.03		< 0.03		< 0.03		< 0.03	
N _{org}	24-h.	12x ročne	2,5	mg/l		1.9		1.9		2.20		1.9		1.8		1.92		2.20		1.92
N _{tot}	24-h.	12x ročne	9	mg/l		8.1		8.40		8.10		8.4		8.1		7.85		8.10		8.40
Aktívny chlór	bodová	12x ročne	0,3	mg/l	< 0.03		< 0.03		< 0.03		< 0.03		< 0.03		< 0.03		< 0.03		< 0.03	
Hydrazín	bodová	1x za 5 rokov	4	mg/l	< 0.01															
Spláškové odpadové vody																				
BSK ₅	bodová	1 x polročne	p20/m70	mg/l					9.5				15.2						9.5	